



太阳能产品认证证书

证书编号：CQC19024216405

申请人名称及地址

江苏固德威电源科技股份有限公司
苏州市高新区紫金路90号

制造商名称及地址

江苏固德威电源科技股份有限公司
苏州市高新区紫金路90号

生产企业名称及地址

江苏固德威电源科技股份有限公司(V017465)
苏州市高新区紫金路90号

产品名称和系列、规格、型号

光伏并网逆变器
GW25K-MT、GW30K-MT、GW36K-MT (见附件)

产品标准和技术要求

NB/T32004-2018

认证模式

产品型式试验+初次工厂检查+获证后监督

上述产品符合 CQC33-461239-2018 认证规则的要求，特发此证。

发证日期：2020年01月03日

本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书，证书首次颁发日期：2019年04月08日



主任： 陆梅



中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>

T 0011408



SOLAR PRODUCT CERTIFICATE

CERTIFICATE NO.: CQC19024216405

NAME AND ADDRESS OF THE APPLICANT

JIANGSU GOODWE POWER SUPPLY TECHNOLOGY CO.,LTD
No.90 Zi Jin Road, SND, Suzhou, China

NAME AND ADDRESS OF THE MANUFACTURER

JIANGSU GOODWE POWER SUPPLY TECHNOLOGY CO.,LTD
No.90 Zi Jin Road, SND, Suzhou, China

NAME AND ADDRESS OF THE FACTORY

JIANGSU GOODWE POWER SUPPLY TECHNOLOGY CO.,LTD (V017465)
No.90 Zi Jin Road, SND, Suzhou, China

PRODUCT NAME, MODEL AND SPECIFICATION

Grid-tied PV Inverter
GW25K-MT、GW30K-MT、GW36K-MT (See Appendix)

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

NB/T32004-2018

TYPE OF CERTIFICATION SCHEMES

Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC33-461239-2018 .

Valid from: Jan.03,2020

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body.

Date of original issued: Apr.08,2019



President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China
<http://www.cqc.com.cn>

T 0011408



太阳能产品认证证书

附 录

第 1 页 共 1 页

证书编号: CQC19024216405

纸 号: 11408

GW25K-MT

直流输入: MPPT 电压范围 200V-950Vdc, 最大直流输入电压 1100Vdc, 最大输入电流 25A*3;
交流输出: 3/N/PE~或 3/PE~, 400V, 50Hz, Max. 40A, 额定交流输出功率 25kW;

GW30K-MT

直流输入: MPPT 电压范围 200V-950Vdc, 最大直流输入电压 1100Vdc, 最大输入电流 25A*3;
交流输出: 3/N/PE~或 3/PE~, 400V, 50Hz, Max. 48A, 额定交流输出功率 30kW;

GW36K-MT

直流输入: MPPT 电压范围 200V-950Vdc, 最大直流输入电压 1100Vdc, 最大输入电流 25A*3;
交流输出: 3/N/PE~或 3/PE~, 400V, 50Hz, Max. 54.5A, 额定交流输出功率 36kW。

注: 此附录与证书同时使用时有效。



主任: _____

陆 楠



中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>